



PO Box 161 Rydalmere BC 1701
p. 02 9890 9999 f. 02 9890 9100
e. info@avidelectrical.com.au
w. www.avidelectrical.com.au
ABN 52 099 750 722

Avid Electrical Services

RCD Test Report

To: Mr A. Customer

Your Business Australia Pty Ltd

TEST REPORT

Operator:**Peter Tolhurst****Test site:****Your Business Australia Pty Ltd****Instrument's data****Type:** EUROTEST COMBO**Ser.No.:** 11010762**Report created on**

15/09/2011

Model: MI 3125B**Producer:** Metrel d.d.

No	Results	
1	Your Business / House DB-HBC / FUSE1 19.04.2011 14:36	PASS
	RCD: Tripout time t: 80.0ms Uc: 0.1V Idn: 30mA type: ~G MUL.: x1 Ulim: 50V	PASS
2	Your Business / House DB-HBC / FUSE3 19.04.2011 14:37	PASS
	RCD: Tripout time t: 79.9ms Uc: 0.5V Idn: 30mA type: ~G MUL.: x1 Ulim: 50V	PASS
3	Your Business / House DB-HBC / FUSE8 19.04.2011 14:38	PASS
	RCD: Tripout time t: 79.8ms Uc: 0.2V Idn: 30mA type: ~G MUL.: x1 Ulim: 50V	PASS
4	Your Business / House DB-HBB / FUSE1 19.04.2011 14:55	PASS
	RCD: Tripout time t: 120.8ms Uc: 0.2V Idn: 30mA type: ~G MUL.: x1 Ulim: 50V	PASS
5	Your Business / House DB-HBB / FUSE2 19.04.2011 14:56	PASS